



FOR SALES AND SERVICE PLEASE CALL:

PTB SALES T :: 626.334.0500
service@ptbsales.com
www.ptbsales.com

DATE SERVICED: _____

VIEW OUR INVENTORY

TV 141 Navigator Vent Valve

Model 969-9834

MANUALE ISTRUZIONI

BEDIENUNGSHANDBUCH

NOTICE DE MODE D'EMPLOI

INSTRUCTION MANUAL

TV 141 Navigator Vent Valve



VARIAN



vacuum technologies

Dear Customer,

Thank you for purchasing a VARIAN vacuum product. At VARIAN Vacuum Technologies we make every effort to ensure that you will be satisfied with the product and/or service you have purchased.

As part of our Continuous Improvement effort, we ask that you report to us any problem you may have had with the purchase or operation of our product. On the back side you find a Corrective Action Request form that you may fill out in the first part and return to us.

This form is intended to supplement normal lines of communications and to resolve problems that existing systems are not addressing in an adequate or timely manner.

Upon receipt of your Corrective Action Request we will determine the Root Cause of the problem and take the necessary actions to eliminate it. You will be contacted by one of our employees who will review the problem with you and update you, with the second part of the same form, on our actions.

Your business is very important to us. Please, take the time and let us know how we can improve.

Sincerely,

Sergio PIRAS

*Vice President and General Manager
VARIAN Vacuum Technologies*

Note: Fax or mail the Customer Request for Action (see backside page) to VARIAN Vacuum Technologies (Torino) - Quality Assurance or to your nearest VARIAN representative for onward transmission to the same address.

CUSTOMER REQUEST FOR CORRECTIVE / PREVENTIVE / IMPROVEMENT ACTION

TO : VARIAN VACUUM TECHNOLOGIES TORINO - QUALITY ASSURANCE

FAX N° : XXXX - 011 - 9979350

ADDRESS: VARIAN S.p.A. - Via F.lli Varian, 54 - 10040 Leinì (Torino) - Italy

E-MAIL : marco.marzio@varianinc.com

NAME _____	COMPANY _____	FUNCTION _____
ADDRESS : _____		
TEL. N° : _____		FAX N° : _____
E-MAIL : _____		
PROBLEM / SUGGESTION : _____ _____ _____ _____ _____ _____		
REFERENCE INFORMATION (model n°, serial n°, ordering information, time to failure after installation, etc.) : _____ _____ _____ _____		
		DATE _____

CORRECTIVE ACTION PLAN / ACTUATION (by VARIAN VTT)	LOG N° _____
_____ _____ _____ _____ _____ _____	

XXXX = Code for dialing Italy from your country (es. 01139 from USA; 00139 from Japan, etc.)

PROCEDURA PER L'INSTALLAZIONE	1
ANLEITUNG ZUR INSTALLATION	3
PROCÉDURE POUR L'INSTALLATION	5
INSTALLATION PROCEDURE	7

PROCEDURA PER L'INSTALLAZIONE DEL KIT TV 141 NAVIGATOR VENT VALVE

GENERALITÀ

Il kit "TV 141 Navigator Vent Valve" comprende un'unità di controllo ed una valvola, che realizzano un sistema completo per la ventilazione automatica della pompa nella fase di spegnimento o nel caso si verifichi una caduta di tensione. La valvola in condizioni di riposo (senza alimentazione) è normalmente aperta. L'attivazione avviene in modo elettromagnetico, mentre il fissaggio (Viton-sealed) viene realizzato tramite un raccordo di tipo M8 con relativo O-ring sul foro per alto vuoto della pompa. L'aria di ingresso nella valvola, viene filtrata tramite un opportuno filtro presente sull'ingresso aria della valvola stessa.

L'unità di controllo viene alimentata dal governo Turbo-V che non è predisposto per il montaggio su rack.

L'unità di controllo viene attivata con un ritardo prefissato di circa 0,8 secondi per evitare ventilazioni inopportune durante una caduta di tensione temporanea e per permettere la chiusura delle valvole di sistema prima della ventilazione.

CARATTERISTICHE TECNICHE

Unità di controllo

- Tensione di ingresso 24 Vdc $\pm$ 10%
- - potenza (max) 2,5 W
- Tensione di uscita (max) 24 Vcc $\pm$ 10%
- - potenza (max) 1,2 W
- Ritardo circa 0,8 secondi
- Temperatura operativa da 0 a 40 °C
- Temperatura di immagazzinamento da -20 a 50 °C


Cavi di connessione

- Ingresso 120 mm (4,72 inch)
- Uscita dalla valvola 200 mm (7,87 inch)

Vent valve

- Stato valvola Normalmente aperta (chiusa quando viene alimentata)
- Connessione di vuoto Raccordo M8
- Filtro ingresso aria Bronzo sinterizzato
- Dimensione foro 0,8 mm (0,03 inch)
- Gamma di pressioni da 10^{-6} mbar a 1 bar (da 10^{-7} Torr a 760 Torr)
- Adattatore ingresso aria $\varnothing$ 6,35 mm ($\frac{1}{4}$ inch)
- Leak rate $\leq 1 \times 10^{-7}$ mbar l/s
- Vita 1 milione di cicli
- Tensione di ingresso 24 Vdc $\pm$ 10%
- Potenza 2,5 W
- Temperatura di bakeout 60 °C
- Peso 140 g (0,3 lbs)


La figura seguente riporta le dimensioni di ingombro della valvola.



Dimensioni in mm

INSTALLAZIONE

In figura sono riportati i vari componenti presenti nel Kit TV 141 Navigator Vent Valve. Tali componenti sono forniti disassemblati; sarà quindi cura del cliente provvedere all'assemblaggio del Kit.



Componenti del Kit




ATTENZIONE

Durante la fase di assemblaggio del kit, fare attenzione a non svitare la ghiera ed il dado di fissaggio della bobina interna alla valvola.

Completato l'assemblaggio, procedere con l'installazione

Rimuovere il tappo a vite presente sulla pompa, quindi fissare la valvola alla pompa utilizzando una chiave esagonale da 16 mm, avendo cura di serrare il dado con una coppia pari a 2,5 Nm.

La figura seguente riporta un esempio d'installazione.



Installazione



ATTENZIONE

Per evitare danneggiamenti della pompa, non serrare il dado con una coppia maggiore a 2,5 Nm.

Dopo aver completato l'installazione meccanica, collegare il cavo di collegamento dalla valvola all'unità di controllo, ed il cavo di collegamento dall'unità di controllo dell'elettrovalvola al controller della pompa.

Per fissare la scatola del controller, utilizzare il velcro in dotazione.

ANLEITUNG ZUR INSTALLATION DER BAUGRUPPE TV 14 NAVIGATOR VENT VALVE

ALLGEMEINES

Die Baugruppe "TV 141 Navigator Vent Valve" umfaßt eine Steuereinheit und ein Ventil, die ein komplettes System zur automatischen Belüftung der Pumpe beim Ausschalten oder bei Spannungsabfall darstellen. In Ruhestellung (ohne Versorgung) ist dieses Ventil normalerweise geöffnet. Es wird elektromagnetisch betätigt, während die Befestigung (Viton-sealed) durch einen Anschluß Typ M8 mit entsprechendem O-Ring an der Bohrung für Hochvakuum der Pumpe erfolgt. Die Eintrittsluft in das Ventil wird durch einen entsprechenden Filter am Lufteinlauf des Ventils gefiltert.

Die Steuereinheit wird durch eine Turbo-V-Steuerung versorgt, die nicht zur Montage auf dem Baugruppenträger vorgesehen ist.

Die Steuereinheit wird mit einer auf ca. 0,8 Sekunden voreingestellten Verzögerung eingeschaltet, um eine unerwünschte Belüftung bei zeitweisem Spannungsabfall zu verhindern und um das Schließen der Ventile des Systems vor der Belüftung zu ermöglichen.

TECHNISCHE DATEN

Steuereinheit

- | | |
|--------------------------|-------------------|
| • Eingangsspannung | 24 Vdc $\pm$ 10% |
| - Leistung (max) | 2,5 W |
| • Ausgangsspannung (max) | 24 Vcc $\pm$ 10% |
| - Leistung (max) | 1,2 W |
| • Verzögerung | ca. 0,8 Sekunden |
| • Betriebstemperatur | von 0 bis 40 °C |
| • Lagerungstemperatur | von -20 bis 50 °C |


Anschlußkabel

- | | |
|----------------------|--------------------|
| • Eingang | 120 mm (4,72 inch) |
| • Ausgang vom Ventil | 200 mm (7,87 inch) |

Vent valve

- | | |
|------------------------|--|
| • Ventilzustand | Normalerweise offen (bei Versorgung geschlossen) |
| • Vakuumzuleitung | M8-Anschluß |
| • Lufteingangsfiter | Sinterbronze |
| • Bohrungsdurchmesser | 0,8 mm (0,03 inch) |
| • Druckwerte | von 10^{-6} mbar bis 1 bar (von 10^{-7} Torr bis 760 Torr) |
| • Adapter Lufteintritt | $\varnothing$ 6,35 mm ($\frac{1}{4}$ inch) |
| • Leak rate | $\leq 1 \times 10^{-7}$ mbar l/s |
| • Lebensdauer | 1 Million Zyklen |
| • Eingangsspannung | 24 Vdc $\pm$ 10% |
| • Leistung | 2,5 W |
| • Bakeout-Temperatur | 60 °C |
| • Gewicht | 140 g (0,3 lbs) |


Aufnachstehender Abbildung sind die Abmessungen des Ventils angegeben.



Abmessungen in mm

INSTALLATION

In der Abbildung sind die verschiedenen Bauteile der Baugruppe TV 141 Navigator Vent Valve dargestellt. Diese Bauteile werden lose geliefert und müssen daher vom Kunden zusammengebaut werden.



Bauteile der Baugruppe




ACHTUNG

Beim Zusammenbau der Baugruppe dürfen der Gewindering und die Befestigungsmutter der Spule im Ventilinneren nicht losgeschraubt werden.

Nach dem Zusammenbau, Installation vornehmen. Verschlussschraube an der Pumpe entfernen, danach Ventil unter Verwendung eines Imbusschlüssels zu 16 mm an der Pumpe befestigen, indem darauf zu achten ist, daß die Mutter mit einem Anziehmoment von 2,5 Nm festgezogen wird.

Nachfolgende -Abbildung stellt ein Installations-beispiel dar.



Installation



ACHTUNG

Um Beschädigungen der Pumpe zu vermeiden, die Mutter nicht mit einem Anziehmoment höher als 2,5 Nm festziehen.

Nach Abschluß der mechanischen Installation, Verbindungskabel vom Ventil zur Überwachungseinheit, sowie Verbindungskabel von der Überwachungseinheit des Elektroventils zum Schaltglied der Pumpe anschließen.

Zum Befestigen des Schaltgehäuses, beigefügtes Klettband verwenden.

PROCÉDURE POUR L'INSTALLATION DU KIT TV 141 NAVIGATOR VENT VALVE

GÉNÉRALITÉS

Le kit "TV 141 Navigator Vent Valve" est composé d'une unité de commande et d'une valve qui forment un dispositif complet pour la ventilation automatique de la pompe pendant la phase d'extinction ou en cas de chute de tension. La valve en état de repos (non alimentée) est normalement ouverte. L'activation est réalisée d'une manière électromagnétique, alors que la fixation (Viton-sealed) est réalisée au moyen d'un adaptateur de type M8 doté d'un joint torique situé sur l'orifice pour vide poussé de la pompe. L'air en entrée de la valve est filtré au moyen d'un filtre monté sur l'entrée d'air de la valve même.

Le dispositif de commande Turbo-V, qui n'est pas conçu pour le montage sur support, alimente l'unité de commande du système.

L'unité de commande est activée avec un retard prédéfini de 0,8 secondes environ, pour éviter toute ventilation inopportune en cas de chute de tension temporaire et pour permettre la fermeture des valves de système avant la ventilation.

CARACTÉRISTIQUES TECHNIQUES

Unité de commande

- Tension en entrée 24 Vdc $\pm$ 10%
- puissance max. 2,5 W
- Tension de sortie max. 24 Vcc $\pm$ 10%
- puissance max. 1,2 W
- Retard 0,8 secondes environ
- Température de service 0 à 40 °C
- Température de stockage -20 à 50 °C


Câbles de connexion

- Entrée 120 mm (4,72 inch)
- Sortie de la valve 200 mm (7,87 inch)

Vent Valve

- Etat de la valve Normalement ouverte (fermée lorsqu'elle est alimentée)
- Connexion de vide Adaptateur M8
- Filtre entrée d'air Bronze fritté
- Dimension orifice 0,8 mm (0,03 inch)
- Plage de pression 10^{-6} mbar à 1 bar (10^{-7} Torr à 760 Torr)
- Adaptateur entrée d'air $\varnothing$ 6,35 mm (¼ inch)
- Leak rate $\leq 1 \times 10^{-7}$ mbar l/s
- Durée de vie 1 million de cycles
- Tension d'entrée 24 Vdc $\pm$ 10%
- Puissance 2,5 W
- Température de "bakeout" 60 °C
- Poids 140 g (0,3 lbs)


Les dimensions d'encombrement de la valve sont indiquées sur la figure ci-après.



Dimensions en mm

INSTALLATION

Les éléments composant le kit TV 141 Navigator Vent Valve sont illustrés sur la figure ci-après. Ces éléments sont livrés désassemblés; par conséquent le client devra effectuer l'assemblage du kit.



Eléments du kit




ATTENTION

En cours d'assemblage du kit faire attention à ne pas dévisser la douille et l'écrou de fixation de la bobine interne de la valve.

Après avoir terminé l'assemblage, installer le kit.

Déposer le bouchon à vis situé sur la pompe, puis fixer la valve à la pompe au moyen d'une clé à six pans de 16 mm et serrer l'écrou au couple de 2,5 Nm.

La figure ci-après illustre un exemple d'installation.



Installation



ATTENTION

Pour éviter tout endommagement de la pompe ne pas serrer l'écrou à un couple supérieur à 2,5 Nm.

Après avoir terminé l'installation mécanique, brancher le câble de connexion de la valve sur l'unité de commande et le câble de connexion de l'unité de commande de l'électrovanne sur le dispositif de commande de la pompe.

Pour fixer le boîtier du dispositif de commande utiliser le velcro livré avec le kit.

TV 141 NAVIGATOR VENT VALVE KIT INSTALLATION PROCEDURE

OVERVIEW

The "TV 141 Navigator Vent Valve" kit, consisting of a control unit and valve, is a complete unit for automatic pump venting when the pump is switched off or during a power failure. The valve is normally open during power off conditions, is electromechanically activated and secured (Viton-sealed) by means of an M8 thread with related O-ring on the high vacuum port. The air input into the valve is filtered by means of a specific filter located on the valve's own air inlet.

The control unit is powered by the Turbo-V controller which is not suitable for rack mounting.

The control unit is activated with a preset delay of approximately 0.8 seconds to avoid undesired venting during a temporary power failure and to allow the closure of the system valves before venting.

TECHNICAL CHARACTERISTICS

Control Unit

- Input voltage 24 Vdc $\pm$ 10%
- - power (max) 2.5 W
- Output voltage (max) 24 Vcc $\pm$ 10%
- - power (max) 1.2 W
- Delay Approx. 0.8 seconds
- Operating temperature 0 to 40 °C
- Storage temperature -20 to 50 °C


Connection Cables

- Input 120 mm (4.72 inches)
- Output from valve 200 mm (7.87 inches)

Vent valve

- Valve status Normally open (closed when power is applied)
- Vacuum connection M8 thread
- Air intake filter Sintered bronze
- Hole dimension 0.8 mm (0.03 inch)
- Pressure ranges 10^{-6} mbar to 1 bar (10^{-7} Torr to 760 Torr)
- Air intake adapter $\varnothing$ 6.35 mm ($\frac{1}{4}$ inch)
- Leak rate $\leq 1 \times 10^{-7}$ mbar l/s
- Life span 1 million cycles
- Input voltage 24 Vdc $\pm$ 10%
- Power 2.5 W
- Bakeout temperature 60 °C
- Weight 140 g (0.3 lbs)


The following figure shows the valve's overall dimensions.



Dimensions in mm

INSTALLATION

The following figure shows the various components of the TV 141 Navigator Vent Valve kit. These components come disassembled and it is therefore up to the customer to assemble the kit.



Kit Components




WARNING

When assembling the kit be careful not to unscrew the coil securing ring and nut inside the valve.

Once the kit is assembled, install it on the pump.

Remove the screw cap from the pump, then secure the valve to the pump using a 16 mm wrench making sure to tighten the nut with a torque equivalent to 2.5 Nm.

The following figure shows an example of installation.



Installation



WARNING

To avoid damaging the pump, do not tighten the nut with a torque greater than 2.5 Nm.

Upon completion of the mechanical installation, attach the connection cable between the valve to the control unit, and the connection cable between the electrovalve control unit to the pump's controller.

Use the velcrose provided to secure the controller box.



Request for Return



1. A Return Authorization Number (RA#) **WILL NOT** be issued until this Request for Return is completely filled out, signed and returned to Varian Customer Service.
2. Return shipments shall be made in compliance with local and international **Shipping Regulations** (IATA, DOT, UN).
3. The customer is expected to take the following actions to ensure the **Safety** of workers at Varian: (a) Drain any oils or other liquids, (b) Purge or flush all gasses, (c) Wipe off any excess residues in or on the equipment, (d) Package the equipment to prevent shipping damage, (for Advance Exchanges please use packing material from replacement unit).
4. Make sure the shipping documents clearly show the RA# and then return the package to the Varian location nearest you.

North and South America

Varian Vacuum Technologies
121 Hartwell Ave
Lexington, MA 02421
Phone : +1 781 8617200
Fax: +1 781 8609252

Europe and Middle East

Varian SpA
Via Flli Varian 54
10040 Leini (TO) – ITALY
Phone: +39 011 9979111
Fax: +39 011 9979330

Asia and ROW

Varian Vacuum Technologies
Local Office

CUSTOMER INFORMATION

Company name:	
Contact person: Name:	Tel:
Fax:	E-Mail:
Ship Method:	Shipping Collect #: P.O.#:
<u>Europe only:</u> VAT reg. Number:	<u>USA only:</u> ☐ Taxable ☐ Non-taxable
Customer Ship To:	Customer Bill To:
.....	
.....	

PRODUCT IDENTIFICATION

Product Description	Varian P/N	Varian S/N	Purchase Reference

TYPE OF RETURN (check appropriate box)

☐ Paid Exchange	☐ Paid Repair	☐ Warranty Exchange	☐ Warranty Repair	☐ Loaner Return
☐ Credit	☐ Shipping Error	☐ Evaluation Return	☐ Calibration	☐ Other

HEALTH and SAFETY CERTIFICATION

Varian Vacuum Technologies **CAN NOT ACCEPT** any equipment which contains **BIOLOGICAL HAZARDS** or **RADIOACTIVITY**. Call Varian Customer Service to discuss alternatives if this requirement presents a problem.

The equipment listed above (check one):

☐ **HAS NOT** been exposed to any toxic or hazardous materials

OR

☐ **HAS** been exposed to any toxic or hazardous materials. In case of this selection, check boxes for any materials that equipment was exposed to, check all categories that apply:

☐ Toxic ☐ Corrosive ☐ Reactive ☐ Flammable ☐ Explosive ☐ Biological ☐ Radioactive

List all toxic or hazardous materials. Include product name, chemical name and chemical symbol or formula.

.....

Print Name: Customer Authorized Signature:

Print Title: Date:/...../.....

NOTE: If a product is received at Varian which is contaminated with a toxic or hazardous material that was not disclosed, **the customer will be held responsible** for all costs incurred to ensure the safe handling of the product, and **is liable** for any harm or injury to Varian employees as well as to any third party occurring as a result of exposure to toxic or hazardous materials present in the product.

Do not write below this line

Notification (RA)#: Customer ID#: Equipment #:

FAILURE REPORT

TURBO PUMPS and TURBOCONTROLLERS

☐ Does not start ☐ Does not spin freely ☐ Does not reach full speed ☐ Mechanical Contact ☐ Cooling defective	☐ Noise ☐ Vibrations ☐ Leak ☐ Overtemperature	POSITION ☐ Vertical ☐ Horizontal ☐ Upside-down ☐ Other:	PARAMETERS Power: Rotational Speed: Current: Inlet Pressure: Temp 1: Foreline Pressure: Temp 2: Purge flow: OPERATION TIME:
TURBOCONTROLLER ERROR MESSAGE:			

ION PUMPS/CONTROLLERS

☐ Bad feedthrough ☐ Vacuum leak ☐ Error code on display	☐ Poor vacuum ☐ High voltage problem ☐ Other
Customer application:	

VALVES/COMPONENTS

☐ Main seal leak ☐ Solenoid failure ☐ Damaged sealing area	☐ Bellows leak ☐ Damaged flange ☐ Other
Customer application:	

LEAK DETECTORS

☐ Cannot calibrate ☐ Vacuum system unstable ☐ Failed to start	☐ No zero/high background ☐ Cannot reach test mode ☐ Other
Customer application:	

INSTRUMENTS

☐ Gauge tube not working ☐ Communication failure ☐ Error code on display	☐ Display problem ☐ Degas not working ☐ Other
Customer application:	

PRIMARY PUMPS

☐ Pump doesn't start ☐ Doesn't reach vacuum ☐ Pump seized	☐ Noisy pump (describe) ☐ Over temperature ☐ Other
Customer application:	

DIFFUSION PUMPS

☐ Heater failure ☐ Doesn't reach vacuum ☐ Vacuum leak	☐ Electrical problem ☐ Cooling coil damage ☐ Other
Customer application:	

FAILURE DESCRIPTION

(Please describe in detail the nature of the malfunction to assist us in performing failure analysis):

NOTA: Su richiesta questo documento è disponibile anche in Tedesco, Italiano e Francese.

REMARQUE : Sur demande ce document est également disponible en allemand, italien et français.

HINWEIS: Auf Aufrage ist diese Unterlage auch auf Deutsch, Italienisch und Französisch erhältlich.

Sales and Service Offices

Argentina

Varian Argentina Ltd.

Sucursal Argentina
Av. Ricardo Balbin 2316
1428 Buenos Aires
Argentina
Tel: (54) 1 783 5306
Fax: (54) 1 786 5172

Australia

Varian Australia Pty Ltd.

679-701 Springvale Road
Mulgrave, Victoria ZZ 3170
Australia
Tel: (61) 395607133
Fax: (61) 395607950

Benelux

Varian Vacuum Technologies

Rijksstraatweg 269 H,
3956 CP Leersum
The Netherlands
Tel: (31) 343 469910
Fax: (31) 343 469961

Brazil

Varian Industria e Comercio Ltda.

Avenida Dr. Cardoso de Mello 1644
Vila Olimpia
Sao Paulo 04548 005
Brazil
Tel: (55) 11 3845 0444
Fax: (55) 11 3845 9350

Canada

Central coordination through:

Varian Vacuum Technologies
121 Hartwell Avenue
Lexington, MA 02421
USA
Tel: (781) 861 7200
Fax: (781) 860 5437
Toll Free: (800) 882 7426

China

Varian Technologies - Beijing

Room 1201, Jinyu Mansion
No. 129A, Xuanwumen Xidajie
Xicheng District
Beijing 1000031 P.R. China
Tel: (86) 10 6608 1530
Fax: (86) 10 6608 1534

France and Wallonie

Varian s.a.

7 avenue des Tropiques
Z.A. de Courtaboeuf – B.P. 12
Les Ulis cedex (Orsay) 91941
France
Tel: (33) 1 69 86 38 13
Fax: (33) 1 69 28 23 08

Germany and Austria

Varian Deutschland GmbH

Alsfelder Strasse 6
Postfach 11 14 35
64289 Darmstadt
Germany
Tel: (49) 6151 703 353
Fax: (49) 6151 703 302

India

Varian India PVT LTD

101-108, 1st Floor
1010 Competent House
7, Nangal Raya Business Centre
New Delhi 110 046
India
Tel: (91) 11 5548444
Fax: (91) 11 5548445

Italy

Varian Vacuum Technologies

Via F.lli Varian, 54
10040 Leini, (Torino)
Italy
Tel: (39) 011 997 9111
Fax: (39) 011 997 9350

Japan

Varian Vacuum Technologies

Sumitomo Shibaura Building, 8th Floor
4-16-36 Shibaura
Minato-ku, Tokyo 108
Japan
Tel: (81) 3 5232 1253
Fax: (81) 3 5232 1263

Korea

Varian Technologies Korea, Ltd.

Shinsa 2nd Bldg. 2F
966-5 Daechi-dong
Kangnam-gu, Seoul
Korea 135-280
Tel: (82) 2 3452 2452
Fax: (82) 2 3452 2451

Mexico

Varian S.A.

Concepcion Beistegui No 109
Col Del Valle
C.P. 03100
Mexico, D.F.
Tel: (52) 5 523 9465
Fax: (52) 5 523 9472

Taiwan

Varian Technologies Asia Ltd.

18F-13 No.79, Hsin Tai Wu Road
Sec. 1, Hsi Chih
Taipei Hsien
Taiwan, R.O.C.
Tel: (886) 2 2698 9555
Fax: (886) 2 2698 9678

UK and Ireland

Varian Ltd.

28 Manor Road
Walton-On-Thames
Surrey KT 12 2QF
England
Tel: (44) 1932 89 8000
Fax: (44) 1932 22 8769

United States

Varian Vacuum Technologies

121 Hartwell Avenue
Lexington, MA 02421
USA
Tel: (781) 861 7200
Fax: (781) 860 5437
Toll Free: (800) 882 7426

Other Countries

Varian Vacuum Technologies

Via F.lli Varian, 54
10040 Leini, (Torino)
Italy
Tel: (39) 011 997 9111
Fax: (39) 011 997 9350

Internet Users:

Customer Service & Technical Support:

vtt.customer.service@varianinc.com

Worldwide Web Site:

www.varianinc.com/vacuum

Order On-line:

www.evarian.com

Representatives in most countries



VARIAN